



Environmental Protection and Growth Management Department
ENVIRONMENTAL ENGINEERING AND PERMITTING DIVISION
1 North University Drive, Mailbox 201, Plantation, Florida 33324 • 954-519-1483 • FAX 954-519-1412

MEMORANDUM

DATE: 5/13/2021

TO: Josie P. Sesodia, Director, PDMD
PDMDInfo@broward.org

FROM: Lorenzo Fernandez, Assistant Director, EEPD 

SUBJECT: Plat Review

The Environmental Engineering and Permitting Division (EEPD) has reviewed the application for modifications to the Development Review Report for the subject plat. Pursuant to the request by the applicant, staff reviewed the information contained in the request, the application, the property survey, the site plan (or conceptual access plan), the recorded plat, and the Development Review Report approved by the County Commission.

REVIEW OF PLAT APPLICATION (please submit electronically)	
Plat Number: 032-MP-19	Folio: 494036020200
Plat Name: Persaud Acres	
Comments Due Date: 12/14/2020	Return Comments To: PDMDInfo@broward.org
Applicant's Request: New Plat Reviews	
Division: Environmental Engineering and Permitting	

Staff proposes the following disposition:

Reviewer's Name: Yvel Rocher

**Program: Domestic and Non-Domestic Wastewater
And Surface Water Management**

Any objection to the plat as submitted.
Answer: No

This plat is subject to the comments noted below.
Answer: Yes

Plat Comments, as needed:

1. The Broward County Domestic Wastewater Licensing Program has no objection to the described plat since there is no sewer available for connection according to the City of Plantation Utilities Department.
2. The Broward County Non-Domestic Wastewater Program has no objection to the described plat because no non-domestic wastewater discharge is anticipated for the site. Nonetheless, should there be proposed non-domestic wastewater discharges, these must meet the criteria under Chapter 27, Article V, Sections 27-193(b)(3)a, 27-193(b)(4)a, 27-194(b), and 27-198(c) of the Broward County Code of Ordinances. Contact the Water and Environmental Licensing Section of the Environmental Engineering and Permitting Division at 954-519-1483 or NDDLICENSE@broward.org for specific code requirements.
3. This site does not require a Broward County Surface Water Management License because it is located outside of the jurisdiction of the Broward County Surface Water Management Licensing Program.

Reviewer's Name: Linda Sunderland

Program: Aquatic and Wetland Resources


Any objection to the plat as submitted.
Answer: Yes

This plat is subject to the comments noted below.
Answer: Yes

Plat Comments, as needed:

1. The Water and Environmental Licensing Section of the Environmental Engineering and Permitting Division has not yet conducted a site inspection on this project; however, aerial photographs and light detection and ranging data (LIDAR) indicate that this property may contain County jurisdictional wetlands. The applicant must request a wetland determination from the Water and Environmental Licensing Section prior to any land clearing or filling. If the site is determined to contain wetlands, an Environmental Resource License will be required prior to any dredging, filling, or other alteration of wetlands. Contact the Environmental Engineering and Permitting Division at 954-519-1483 or AWRLicense@broward.org for specific code requirements.
2. The Water and Environmental Licensing Section of the Environmental Engineering and Permitting Division encourages all invasive exotic vegetation including Melaleuca, Brazilian pepper, Australian pine and others as listed in the Exotic Pest Plant Council's List of Florida's Most Invasive Species to be removed during the development process, and a management plan may be necessary to control re-invasion of same. In addition, landscape material should not include any plants considered to be invasive of South Florida's native plant communities. The Exotic Pest Plant Council's List of Florida's Most Invasive Species is available at <https://www.fleppc.org/list/list.htm>.
3. Other activities regulated under Chapter 27, Article XI of the Natural Resource Protection Code (e.g., lake or canal excavation, installation of headwalls, end walls, or outfalls) may require an Environmental Resource License. Prior to undertaking surface disturbing activities, contact the Environmental Engineering and Permitting Division at 954-519-1483 or AWRLicense@broward.org for specific code requirements.

Reviewer's Name: Peter Burke	Program: Tree Preservation
-------------------------------------	-----------------------------------



Any objection to the plat as submitted.
Answer: No

This plat is subject to the comments noted below.
Answer: Yes

Plat Comments, as needed:

This site does not fall under the jurisdiction of the Broward County Tree Preservation and Abuse Ordinance.

Reviewer's Name: David Vanlandingham	Program: Clean-Up and Waste Regulation
---	---



Any objection to the plat as submitted.
Answer: No

This plat is subject to the comments noted below.
Answer: Yes

Plat Comments, as needed:

Not a known contaminated site or within 1/4 mile of a contaminated site; not a waste regulation facility or a known old landfill/dump.

Reviewer's Name: Robert Wong

Program: Air Program

Any objection to the plat as submitted.
Answer: No

This plat is subject to the comments noted below.
Answer: Yes

Plat Comments, as needed:

Submit a Statement of Responsibilities Regarding Asbestos (SRRA) electronically at ePermits.broward.org at least 10 working-days before commencing work on demolition and/or renovation of the existing building. More information on the asbestos requirements can be found at:
<http://www.broward.org/ePermits/Search/Pages/PermitDetails.aspx?permitID=395>.
For assistance, contact Broward County's asbestos program at AsbestosHelp@broward.org or call 954-519-0340.