

Mission:  
To protect, promote & improve the health  
of all people in Florida through integrated  
state, county & community efforts.



Scott A. Rivkees, MD  
State Surgeon General

Vision: To be the Healthiest State in the Nation

**Date:** 4/30/2021  
**To:** Planning and Development Management Division  
**From:** OSTDS Division – Environmental Engineering  
Florida Department of Health – Broward County  
**Subject:** Plat/Site/Vacation/Rezoning Number: 032-MP-19  
Plat/Site/Rezoning Name: PERSAUD ACRES  
**Date Due:** 12/3/2019

A review has been conducted and FDOH-Broward comments are as follows:

## WATER SUPPLY

Well(s)  
Well Construction Permit(s) will need to be obtained through FDOH-Broward.

Public – Water Treatment Plant City of Plantation

Plant Capacity \_\_\_\_\_MGD

Maximum Daily Flow \_\_\_\_\_MGD      Maximum Daily Flow Date \_\_\_\_\_

Available Plant Capacity (based upon maximum daily flow) 0 MGD

Property Water Usage: \_\_\_\_\_MGD

Unable to calculate

There is Sufficient plant capacity to serve this project at this point in time.

There is Insufficient plant capacity to serve this project at this point in time.

## **SEWAGE DISPOSAL**

- Approved sanitary sewage collection facility, specified on application.
- Septic Tank(s) intended to be used.  
Prior to any construction or building permits, the required Septic Tank Permit(s) must be issued by our Department. Complete compliance with Chapter 64E-6 of the Florida Administrative Code and Broward County Code Chapter 34, Article 11 1/2 Water and Septic Tank Ordinance must be effected.

This project as submitted will be limited to 12,425 gallons per day (gpd) sewage flow, as provided in Chapter 64E-6 of the Florida Administrative Code (FAC) or Chapter 34, Article 11 1/2 Water and Septic Tank Ordinance.

## **Additional Information and/or Comments:**

Amendment requested original comments was sent in 2019. Lot 1 is 43,661 sqft/1.0 Acre  

---

and the flow will be limited to 2,500 gpd, Lot 2 is 43,661/1.0 Acre and the flow will be limited to 2,500 gpd  

---

and Lot 3 is 118,806/2.73 Acres and the flow will be limited to 6,825 gpd. The total lot size of the plat is  

---

216,149 sqft./4.97 Acres and the flow will be limited to 12,425 according to the information provided by Broward County.  

---

## **Conclusions of Review**

1.  No objection as submitted
2.  No objection, subject to comments noted above.
3.  Objection-refer to comments noted above.
4.  Our department is unable to comment upon the availability and adequacy of a water supply, or the provision of sewage disposal, as the providers for the same were not specified on the submitted application materials.