

Board of County Commissioners, Broward County, Florida
Environmental Protection and Growth Management Department
Planning and Development Management Division
DEVELOPMENT REVIEW REPORT

PROJECT DESCRIPTION

Name:	BW ANDREWS	Number:	008-MP-19
Applicant:	BW Atlantic Andrews, LLC	Comm. Dist.:	2
Agent:	Caulifield & Wheelers, Inc.	Sec/Twp/Rng:	34-48-42
Location:	Northwest Corner of Atlantic Boulevard and Andrews Avenue Extension	Platted Area:	2.2 Acres
City:	Pompano Beach	Gross Area:	N/A
Replat:	N/A		

LAND USE

Existing Use:	Vacant	Effective Plan:	Pompano Beach
Proposed Use:	Convenience Store/Service Station with 16 Fueling Positions	Plan Designation:	Industrial. See attached comments from the Planning Council.
Adjacent Uses:		Adjacent Plan Designations:	
North:	Industrial	North:	Industrial
South:	Industrial	South:	Transportation
East:	Industrial	East:	Industrial
West:	Industrial	West:	Industrial
Existing Zoning:	I-1	Proposed Zoning:	I-1

RECOMMENDATION (See Attached Conditions)

APPROVAL: Subject to staff recommendations and conditions which shall assure compliance with the standards and requirements of Chapter 5, Article IX, of the Broward County Code of Ordinances.

Meeting Date: 02/11/20
Action Deadline: 03/11/20
Deferral Dates:

Prepared: HWC
Reviewed:
Approved:

SERVICES

Wastewater Plant:	BCUD (09/19)	Potable Water Plant:	Pompano Beach (14/18)
Design Capacity:	95.0000 MGD	Design Capacity:	50.000 MGD
12-Mo. Avg. Flow:	69.9000 MGD	Peak Flow:	19.100 MGD
Est. Project Flow:	0.0200 MGD	Est. Project Flow:	0.001 MGD

Comments: Sufficient capacity exists at this time. Comments: Sufficient capacity exists at this time.

PARKS

SCHOOLS			Land Dedication	Impact Fee	Admin. Fee
Dwelling Units	Impact Fee	Local:	N/A	N/A	N/A
N/A	N/A	Regional:	N/A	N/A	N/A

TRANSPORTATION

Concurrency Zone: South Central	Trips/Peak Hr.	Transit Concurrency Fee	Road/Admin. Fee
Res. Uses:	N/A	N/A	N/A
Non-res. uses:	161	*	N/A
Total:	161	*	N/A

* See Staff Comment No. 3
See Finding No. 1
See Staff Recommendation No. 1

BW ANDREWS 20-110
008-MP-19

STAFF COMMENTS

- 1) Staff findings and recommendations pertaining to this plat are based on the use being convenience store/service station with 16 fueling positions. This property is being platted because it does not qualify for an exception to the mandatory platting rule and the plat boundaries are not specifically delineated on a recorded plat.
- 2) Trafficways approval is valid for 10 months. Approval was received on May 23, 2019.
- 3) This plat is located within a Transportation Concurrency Management Area. In accordance with Land Development Code, transportation concurrency fees will be assessed in accordance with the fee schedule specified in the ordinance during the review of construction plans submitted for County environmental review approval and must be paid on the date of building permit issuance.
- 4) This plat is not located in a Wellfield Zone of influence as described in the Broward County Wellfield Protection Ordinance 84-60, as amended, and as incorporated into Broward County Code of Ordinances, Chapter 27, Article XIII.
- 5) This plat is located in the City of Pompano Beach and is in a dependent water control district under the jurisdiction of the Water and Environmental Licensing Section of the Environmental Engineering and Permitting Division. Surface water management plans must meet the criteria contained in Chapter 27 - Article V of the Broward County Code of Ordinances and the criteria of the Water Control District No. 3. A surface water management license from the Water and Environmental Licensing Section will be required prior to any construction. Any discharges to ground or surface waters, excluding stormwater, will require review and approval by the Water and Environmental Licensing Section of the Environmental Engineering and Permitting Division prior to discharge. Any vehicle washing facility not connected to a sanitary sewer system must recycle 100% of its wash water and no discharge to the drainage system will be permitted.
- 6) The Water and Environmental Licensing Section of the Broward County Environmental Engineering and Permitting Division has advised that a Wastewater Collection/Transmission System License will be required prior to constructing, expanding or altering either a gravity sanitary sewer, a sanitary force main or a pump station, per Chapter 27, Article V of the Broward County Code of Ordinances regarding Water Resource Management. Wastewater receiving lift stations and force mains are critical components of the conveyance system. As part of the licensing process, adequate capacity will need to be demonstrated for the receiving off-site sanitary sewer conveyance system. The size and scope of flows for the proposed domestic wastewater generation from this plat will likely be substantial and variable; this may impose additional needs for advance planning, permitting, and construction for both onsite and offsite components of the conveyance system. For additional information, contact the Water and Environmental Licensing Section at 954-519-1483.

- 7) Review of available information by staff of the Water and Environmental Licensing Section of the Broward County Environmental Engineering and Permitting Division indicates that, at this time, there are no wetlands within the boundaries of the plat. Therefore, a Conceptual Dredge and Fill Review Report is not required. Based upon the present conditions within the site, filling of the land area will not require an Environmental Resource License. Other activities, e.g., lake or canal excavation, regulated under Article XI of the Natural Resource Protection Code may require a license. The applicant is encouraged to contact the Water and Environmental Licensing Section at 954-519-1483 to determine if, and what type of, license may be required prior to undertaking surface disturbing activities.
- 8) The Water and Environmental Licensing Section encourages that all invasive exotic vegetation including Melaleuca, Brazilian-pepper, Australian pine and others as listed in the Exotic Pest Plant Council's List of Florida's Most Invasive Species be removed during the development process, and advises that a management plan may be necessary to control re-invasion of same. In addition, landscape materials should not include any plants considered to be invasive of South Florida's native plant communities. The Exotic Pest Plant Council's List of Florida's Most Invasive Species is available from the Water and Environmental Licensing Section of the Environmental Engineering and Permitting Division.
- 9) This site is not included in the Protected Natural Lands Inventory and is not adjacent to a site in the inventory. The Protected Natural Lands Inventory is a comprehensive database of public and private native vegetative communities that have been protected through acquisition or regulatory mechanisms and are managed for conservation purposes. Please contact Paul Krashefski of the Environmental Planning and Community Resilience Division concerning the inventory, which provides information regarding the ownership and management of each of the Protected Natural Lands. He can be reached at (954) 519-1297 or pkrashefski@broward.org
- 10) Review of aerial photographs indicates that the subject site contains tree canopy. If trees are to be removed or relocated, development of the site must comply with the Tree Preservation regulations of the City of Pompano Beach. The applicant is encouraged to minimize the number of trees to be removed by incorporating existing trees in the site plan. If trees cannot be incorporated into the site plan in their current location, the applicant is encouraged to relocate trees, especially those of specimen size and quality.
- 11) A Tree Removal License may be required for any tree removal or relocation located in the North Andrews Avenue Right-of-Way. Contact the Water and Environmental Licensing Section of the Environmental Engineering and Permitting Division at 954-519-1483 for specific license requirements.
- 12) An Environmental Resource License may be required for any activities regulated under Article XI of the Natural Resource Protection Code. Contact the Water and Environmental Licensing Section of the Environmental Engineering and Permitting Division at 954-519-1483 for specific license requirements.

Continued

- 13) A Storage Tank License may be required if there will be fuel storage associated with the service station. Contact the Environmental and Consumer Protection Division at 954-519-1260 for specific license requirements.
- 14) The subject plat is in the vicinity of known contaminated sites and the following should be noted: For any site that overlies or contains potential or actual sources of pollution to ground or groundwater, the Environmental Engineering and Permitting Division's approval of an application for a building permit or approval to construct or alter shall not be granted until the Environmental Assessment and Remediation Section of the Environmental Engineering and Permitting Division is satisfied that the construction or alteration will not interfere with the cleanup of the contaminants on site [Section 27-66(h) Broward County Code of Ordinances]. It should also be noted that the Environmental Assessment and Remediation must approve any dewatering activities at this site.
- 15) Plat approval does not infer any approval to connect to any wastewater collection, treatment, or disposal system. Nor does it infer that sufficient capacity will exist at time of building permit approval. Approval to connect to such systems is approved by the Environmental Engineering and Permitting Division as a prerequisite to, and just prior to, approval of building permits by the appropriate building department for any structures that are to be built on the platted site. These comments do not indicate waiver of approval of any other permit that may be required for other aspects of the project.
- 16) This property is within 20,000 feet of the Fort Lauderdale Executive Airport and the Pompano Beach Municipal Airport. Any proposed construction on this property or use of cranes or other high-lift equipment must be reviewed to determine if Federal Aviation Regulation Part 77, Florida Statutes, Chapter 333 and/or the Broward County Airport Zoning Ordinance apply. Based on the location of the proposed project, the FAA may need to review to determine whether the project is a potential hazard to aviation. To initiate the Federal Aviation Review, access the FAA Web Page at: <http://oeaaa.faa.gov/oeaaa/external/portal.jsp>. For additional information, contact the Broward County Aviation Department at 954-359-6170.
- 17) Review of available information including archival documents, maps, the Broward County Land Use Plan, and the Florida Master Site File by the County's consulting archaeologist indicates that the proposed development is not likely to impact any significant historical or archaeological resources, and the consulting archaeologist has no objections to this application. The archaeologist notes that this property is located in the City of Pompano Beach and outside the jurisdiction of Broward County Historic Preservation Ordinance 2014-32. The property owner/agent is advised to contact David L. Recor, Director of City of Pompano Beach's Development Services Department at 954-786-7921 to seek project review for compliance with the municipal historic preservation regulations. In the event any unmarked human burial remains are discovered, pursuant to Florida Statute Chapter 872.05, all activity that may disturb the unmarked burial shall cease immediately, and the district medical examiner shall be notified. Such activity shall not resume unless specifically authorized by the district medical examiner or State Archaeologist. The Broward County medical examiner can be notified at either 954-357-5200 or med_exam_trauma@broward.org.

- 18) Openings or improvements on functionally classified State Roads are subject to the "Rules of the Department of Transportation Chapter 14-97 State Highway System Access Management Classification System and Standards." In accordance with Section 5-189(b)(5) of the Land Development Code, the applicant has submitted the attached pre-application approval letter from the Florida Department of Transportation.
- 19) This site is currently serviced by BC Transit Route 42 on Atlantic Boulevard (SR 814) and bus stop ID #5551 that has an existing pre-fabricated shelter that is to be relocated as part of the off-site improvements.
- 20) The attached memorandum from the Highway Construction and Engineering Division, Traffic Engineering Division and Transit Division indicates that they have reviewed the plat application and have determined that the comments and recommendations are required with respect to the safe and adequate access standards of the Broward County Land Development Code. The recommendations for this plat may be modified if significant conflicts are identified by details included in the submitted construction plans.
- 21) The Broward County Planning Council has received written documentation from the City of Pompano Beach that convenience store/service station are permitted within the industrial land use category. See the attached comments regarding this plat's compliance with the effective Land Use Plan.
- 22) The applicant is advised that, in accordance with Section 125.022, Florida Statutes, the issuance of a development permit by the County does not in any way create any rights on the part of the applicant to obtain a permit from a state or federal agency and does not create any liability on the part of the County for issuance of the permit if the applicant fails to obtain requisite approvals or fulfill the obligations imposed by a state or federal agency or undertakes actions that result in a violation of state or federal law. Specific questions regarding any of the above comments may be directed to each review agency contact person. A complete list of agency contact information can be accessed on the Planning and Development Management Division's web page at:
www.broward.org/Planning/FormsPublications/Documents/ReviewAgencies.pdf

FINDINGS

CONCURRENCY REVIEW

- 1) This plat is located within the Northeast Transportation Concurrency Management Area. This district meets the regional transportation concurrency standards specified in Section 5-182(a)(5)a) of the Land Development Code.
- 2) This plat satisfies the solid waste disposal concurrency requirement of Section 5-182(h) of the Broward County Land Development Code.

GENERAL RECOMMENDATIONS

Continued

- 1) Transportation concurrency fees will be assessed during the review of construction plans submitted for County environmental review approval by the Development and Environmental Review Section of the Planning and Development Management Division, in accordance with the fee schedule specified in the Land Development Code and must be paid on the date of building permit issuance.
- 2) Place a note on the face of the plat, preceding the designated municipal official's signature, reading:

All applicable concurrency/impact fees for the construction, expansion, and/or conversion of a building within this plat shall be paid on the date of building permit issuance.

- 3) Place a note on the face of the plat reading:
 - A) If a building permit for a principal building (excluding dry models, sales and construction offices) and first inspection approval are not issued by **February 11, 2025**, then the County's finding of adequacy shall expire and no additional building permits shall be issued until such time as Broward County shall make a subsequent finding that the application satisfies the adequacy requirements set forth within the Broward County Land Development Code. The owner of the property or the agent of the owner shall be responsible for providing evidence to Broward County from the appropriate governmental entity, documenting compliance with this requirement within the above referenced time frame; and/or
 - B) If construction of project water lines, sewer lines, drainage, and the rock base for internal roads have not been substantially completed by **February 11, 2025**, then the County's finding of adequacy shall expire and no additional building permits shall be issued until such time as Broward County shall make a subsequent finding that the application satisfies the adequacy requirements set forth within the Broward County Land Development Code. The owner of the property or the agent of the owner shall be responsible for providing evidence to Broward County from the appropriate governmental entity, documenting compliance with this requirement within the above referenced time frame.
 - C) This plat is restricted to convenience store/service station with 16 fueling positions.

This note is required by Chapter 5, Article IX, Broward County Code of Ordinances, and may be amended by approval of the Broward County Board of County Commissioners. The notation and any amendments thereto are solely indicating the approved development level for property located within the plat and do not operate as a restriction in favor of any property owner including an owner or owners of property within this plat who took title to the property with reference to this plat.

- D) Any structure within this plat must comply with Section 2.1.f., Development Review Requirements, of the Broward County Land Use Plan, regarding hazards to air navigation.

- 4) If this item is approved, authorize the Mayor to sign an order approving this agenda item subject to staff findings, comments, and recommendations.