



Public Works Department

HIGHWAY CONSTRUCTION AND ENGINEERING DIVISION

1 N. University Drive, Box B300, Plantation, Florida 33324-2038 • 954-577-4555 • FAX 954-357-5715

M E M O R A N D U M

DATE: May 18, 2026

TO: Darby Delsalle, Director
Housing and Urban Planning Division

FROM: David (D.G.) McGuire, Plat Section Manager
Plat Section, Highway Construction and Engineering Division

Jason McKoy, Staff Engineer
Capital Programs Division, Broward County Transportation Department

SUBJECT: Application for New Plat – Letter to Proceed
Monroe Place (016-MP-25)

The Highway Construction and Engineering Division, Traffic Engineering, and the Transportation Department, Transit Division have reviewed the application for a new plat. Our review included the information contained in the application, the property survey, the site plan (or conceptual access plan), and any previously recorded plats.

As a result of our review, staff has determined that the comments and recommendations are required with respect to the safe and adequate access standards of the Broward County Land Development Code.

F.S. 177 PLAT REVIEW COMMENTS

The following comments note the corrections necessary for the plat mylar to comply with the requirements of Florida Statutes Chapter 177. If additional clarification is necessary, please contact Jason Espinosa at (954) 577-4593 or via email at JESPINOSA@BROWARD.ORG.

Please note that additional changes made to the plat mylar beyond this list of corrections may necessitate additional review time; delay recordation; and result in additional review fees.

All resubmittals shall include a paper copy of the plat with changes from the original plat review application highlighted.

1 SURVEY DATA

- A. Square footage shall be shown for each parcel. The total acreage shall be accurate to the nearest square foot.
 - 1. Review and revise the net area shown for Parcel A. It states that it is the net area, but it is the gross area.
- B. Full dimensioning and square footage shall be shown on all dedicated RIGHT-OF-WAY.
- C. P.R.M.s shall be shown at every change of direction, not more than 1,400 feet apart, with a minimum of 4 indicated. P.R.M.s shall be labeled “Found” or “Set”. P.C.P.s as appropriate.
 - 1. Add PRM to PRM labels for the 44.99’ distance along the south boundary and the 71.33’ distance along the east boundary of the plat.
- D. The plating surveyor shall submit Certified Corner Records for section corners used in preparation of the plat to both the State and Broward County. County staff will confirm submittal to the State prior to plat recordation. For section corners which have Certified Corner Records on file, the surveyor shall submit an affidavit confirming that the Section corner was found to be substantially as described in the most recently available certified corner record. Standard affidavit forms are available at:
<http://www.broward.org/BCEngineering/Pages/PlatSectionForms.aspx>.
- E. The surveyor shall submit digital plat information (after all corrections are completed and Highway Construction & Engineering Division staff requests digital information).

2 RIGHT OF WAY DELINEATION AND DEDICATION LANGUAGE

- A. Dedication language shall clearly dedicate all right-of-way and easements shown on the plat.
 - 1. In the dedication language remove the following text “OF A PORTION OF THE SOUTHWEST 1/4 OF SECTION 15, TOWNSHIP 51 SOUTH, RANGE 42 EAST, BROWARD COUNTY, FLORIDA.”

3 TITLE CERTIFICATION AND DEDICATION SIGNATURE BLOCKS

- A. The title shall be updated for review of any agreements and the recordation process. Standard format for Title Certificates, Opinions of Title, the Adjacent Right-of-way Report, and a Guide to Search Limits of Easements and Right-of-way may be obtained by contacting the Highway Construction & Engineering Division or by visiting our web site:
<http://www.broward.org/BCEngineering/Pages/PlatSectionForms.aspx>

4 DRAFTING AND MISCELLANEOUS DATA

- A. Relocate the Plat Notes from page 1 to page 2.

5 HIGHWAY CONSTRUCTION & ENGINEERING DIVISION INTERNAL PROCEDURES
(These items are required for plat recordation but are completed by County staff)

- A. Planning Council Executive Director or Designee Signature
- B. Completion of all POSSE Inputs; Impact Fee and Security reports printed
- C. County Surveyor Signature
- D. PRM's Verified
- E. Development Order, Urban Planning Division Director Signature
- F. Highway Construction and Engineering Director Signature